

Addendum 02

Date: May 16, 2023
Project: UHN Cardiac Care Unit Renovation
Project Number: N662330007

This addendum is to be read with and constitutes part of the tender document.

Instructions:

1. Amend your copy of the tender/quotation/proposal in accordance with the detail below
2. Retain one copy for your file; sign and return a second copy and attach to your submission as confirmation that the Addendum was taken into account in your bid submission.
3. Failure to sign and return this form may result in a non-compliant bid.

Questions & Responses:

1. Q: What is the specification for the Vinyl Kick Plates? Are the existing Vinyl kick plates to be re-used for the Refurbished Doors?

R: Alternate price # 1 (re-use existing door slabs, cut in new windows): Yes.
Base bid: No, see clarification below.

Refer to Specification Section 08710 Finish Hardware, Item 2.1.(8)

Delete: Vinyl kick plates w/ adhesive mounting, match existing

Add: Vinyl kick plates w/ adhesive mounting - Koroguard P400 Vinyl Kick Plate, or equal and approved. Kick plate colour to match existing.

2. Q: Will the patient camera be mounted on the ceiling or the wall? What sort of rough-in is expected for this scope?

R: Install backbox on ceiling tile for camera support. Provide conduit stub from camera location (along wall) to nursing station location.

Clarification:

Addendum 01 - Question 11:

Q: Who will perform the removal and moving of Assisted Bathtub from Room 2279 to its designated transfer/storage location?

R: ~~All fixtures within 2279 are noted as to be removed and disposed of by the contractor—see drawing # D1 (red dashed lines).~~ All fixtures within 2279 are noted as to be removed by the contractor and turned over to the owner (FM) except for the Assisted Bathtub, which will be removed by the owner – see drawing # D1 (red dashed lines).

End of Addendum