

Addendum No: 1
Date: April 15, 2024
Owner: Northern Health
Stantec # 144320012

This addendum is to be read with and constitutes part of the tender document.

0.0 GENERAL

Not in use

1.0 SPECIFICATIONS

Division 01 21 00 Cash Allowances: (pg-19)

Update:

No1. Unforeseen site condition \$10,000.00

No2. Unforeseen Fire alarm and Smoke/Fire Dampers \$24,000.00

Remove:

No3. Lighting Control Devices

2.0 DRAWINGS

Not in use

3.0 CLARIFICATIONS

Q: there is a cash allowance for PA Speakers listed in the notes on Electrical drawing E001, but it is not listed in the front end cash allowances. Please clarify if this Cash allowance applies to this project.

A: Yes. Cash allowance applies to new PA speakers' connection to location outside of renovation area if required.

Project #N662030002
UHN Prince George
UHN Cardiac Diagnostic Phase 2 (Burn)

Issued for Tender – Addendum #1

Page 2 of 2

Q: there is a cash allowance in the front end doc's to cover the Lighting Control System upgrades, but it is not mentioned on the electrical drawings. Please clarify if this cash allowance applies to this project

A: No. Remove lighting control devices cash allowance. Bid to include complete lighting system design as per electrical drawing.

Stantec Architecture Ltd.

Eleonore Leclerc
Principal, Architect AIBC, SAA, OAA

Cell: 604 369-6753
Eleonore.Leclerc@stantec.com

END OF ADDENDUM #1