



Project/File: 115622108 – BVH Electrical Upgrade  
Addendum No.: #02  
Date: August 28, 2024  
To: Jay Dupras

This addendum is to be read with and constitutes part of the tender document.

**1.1.1 INSTRUCTIONS:**

1. Amend your copy of the tender/quotation/proposal in accordance with the detail below.
2. Retain one copy for your file; sign and return a second copy and attach to your submission as confirmation that the Addendum was taken into account in your bid submission.
3. Failure to sign and return this form may result in a non-compliant bid.

**1.1.2 DETAILS OF THE ADDENDUM:**

Change generator diesel type from Type 2 to Type 1 Winter Grade.

Siemens has been approved as an acceptable equipment supplier.

Regards,

**STANTEC CONSULTING LTD.**

**Thys Fourie** P.Eng MBL  
Principal, Electrical Engineer

Direct: 604 696-8144  
Mobile: 778 838-0194  
Fax: 604 696-8100  
[thys.fourie@stantec.com](mailto:thys.fourie@stantec.com)

Attachment: N/A

Firm Name: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Date: August 28, 2024

