



Vancouver

Montreal

138 W 8th Avenue
Vancouver, BC V5Y 1N2
T. 778.330.1139 F. 778.327.6844

www.goTAD.ca

DATE

October 1, 2024

ADDENDUM No.

No. 02

PROJECT No.

BC-1352

TITLE AND DESCRIPTION OF PROJECT

NUCLEAR MEDICAL SCAN ROOM RENOVATION - 1475 EDMONTON STREET PRINCE GEORGE, BC V2M 1S2

This Addendum forms part of the contract documents and is to be read, interpreted, and co-ordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

MECHANICAL

1. Clarifications

1.1. *QUESTION: Is duct cleaning required Section 23 05 00 .5 makes it sound like they only need cleaned if dirty from construction?*

ANSWER: Duct cleaning is required. The contractor shall allow for duct cleaning as per the mechanical specifications.

Prepared by : Tanveer Faisal Anjum, Project Manager

Reviewed and Signed by: J. Robert Thibodeau AIBC

J. Robert Thibodeau AIBC

End of Addendum 02