

---

# AMENDMENT 01

---

**Date:** September 8, 2025  
**To:** All Bidders  
**From:** Gloslee, William, Biomedical Engineering  
**Re:** RFQ – UHN X-Ray Room #3 Renovation, N662650005

See below for Q&A to the RFQ dated August 21, 2025.

**Q1:** It was mentioned that the ADO needs 2 new card readers installed as well. There is no mention of this on the prints. Where is the access control panel located so that we can feed the card readers?

**A1:** This door is currently controlled by the Kantec Systems, so there is a Door Swipe Access on it. The contractor will only have to tie this unit into the Auto Door Opener.

**Q2:** In regards to the discussion for the flooring at the site meeting are we just patching removed wall areas and misc coving or changing out the entire room?

**A2:** The contractor will just patch newly installed and removed wall area, not the entire floor.

**Q3:** Query From Plumbing Trade: Please confirm the location of the sink that needs to be installed and are there existing services there? or do we need to add DWV and Domestic water to a new location? We do not see any further scope than this?

**A3:** The new sink will replace the existing sink and there is both domestic cold water and hot water located at that sink.

**END OF AMENDMENT**