

---

## AMENDMENT 02 Rev 1

---

**Date:** September 10, 2025  
**To:** All Bidders  
**From:** Gloslee, William, Biomedical Engineering  
**Re:** RFQ – UHN X-Ray Room #3 Renovation, N662650005

See below for further clarifications for Amendment 02 Q&A.

**Q1:** The Electrical Requirement 4 states that Code Buttons need to be moved, the plans do not indicate the actual quantities and locations. Could I get a confirmation on both?

**A1 Rev:** There is only one code enclosure, around 8"x 6". That enclosure has 2 buttons inside it. It is to be moved 8" to the left of their current location.

**END OF AMENDMENT**