
Date: April 28, 2026

This Addendum varies the Bidding and Contract Documents dated March 26, 2026 and titled:

Project Name: UHN – Lab Histology Ventilation Upgrade
Project Number: 115625050

This Addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all work contained herein shall be included in the Contract sum. The following revisions supersede the information contained in the original specifications and drawings issued for the above-named project. Acknowledge receipt of this Addendum by inserting its number in the STIPULATED PRICE BID FORM.

1.0 GENERAL

1.1 ARCHITECTURAL:

Not in use.

1.2 MECHANICAL:

Not in use.

1.3 ELECTRICAL:

Not in use.

2.0 SPECIFICATIONS

Not in use.

3.0 DRAWINGS

Not in use.

4.0 QUESTIONS AND ANSWERS

Question: Just want to make sure the above hood portion is included with the 2 owner supplied grossing stations?

Is there a mechanical schedule for the CH-1 hood to be supplied by the contractor?

Answer: No. Hood is not supplied with grossing station. "Canopy Hood (CH-1) to be supplied and installed by mechanical contractor as noted on the mechanical drawings. Equipment schedule for canopy hood is provided in Addendum #01 issued April 8th, 2026."

Question: Can we please have some specification for the CH-1 hood?

Answer: provided in Addendum #01 issued April 8th, 2026.”

End of Addendum No. 5

Stantec:

Eno Muho

Arch. Design Coordinator

Direct: 604 696-8459

Eno.Muho@stantec.com

Stantec

1100-111 Dunsmuir Street

Vancouver BC V6B 6A3